

THE BUILDING OFFSETS AS SHOWN ON THIS PLAN ARE NOT TO BE USED FOR THE ESTABLISHMENT OF PROPERTY LINES OR FOR THE ESTABLISHMENT OF ANY PROPOSED CONSTRUCTION UNLESS SAID CONSTRUCTION IS SHOWN HEREON.

THIS PLAN WAS PREPARED FOR THE EXCLUSIVE USE AND PURPOSE FOR THE PARTY STATED HEREON AND SHALL NOT BE USED BY ANY THIRD PARTY WITHOUT THE EXPRESSED WRITTEN PERMISSION OF GUERRIERE AND HALNON, INC.

LOCAL UPGRADE APPROVAL REQUEST:
310 CMR 15.405 (g)

Reduction of system location setbacks otherwise established in 310 CMR 15.211 for property lines provided that a survey of the property line shall be required if a component is to be placed within five feet of the property line, and no such reduction shall result in the soil absorption system being located less than ten feet from a soil absorption system on an abutting property.

REDUCTION OF SOIL ABSORPTION SYSTEM SETBACK FROM PROPERTY LINE FROM 10 FEET TO 7.1'.

SYSTEM TIES		
	A	B
① PUMP CHAMBER INLET COVER	24.5'	33.8'
② PUMP CHAMBER OUTLET COVER	25.5'	38.2'
③ DISTRIBUTION BOX	60.3'	75.8'
④ 90° PIPE BEND	63.7'	79.9'
⑤ END OF BED LATERAL	90.2'	101.8'
⑥ END OF BED LATERAL	84.9'	94.3'
⑦ 90° PIPE BEND	56.9'	70.4'

	PROPOSED DESIGN	AS-BUILT DESIGN
TOP OF FOUNDATION (EXISTING)	332.70	N/A
SLAB ELEVATION	N/A	N/A
INV. AT FOUNDATION	327.27	N/A
INV. AT SEPTIC TANK INLET (EXISTING)	N/A	N/A
INV. AT SEPTIC TANK OUTLET (EXISTING)	N/A	326.38
INV. AT PUMP CHAMBER INLET	326.55	326.21
INV. AT PUMP CHAMBER OUTLET	326.30	326.49
INV. AT DIST. BOX INLET	327.72	327.84
INV. AT DIST. BOX OUTLET	327.55	327.81
INV. AT BEGIN OF BED	327.45	327.58
INV. AT END OF BED	327.30	327.28
ELEV. AT BOTTOM OF STONE	326.80	327.78
ELEV. OF GROUND WATER	321.6	N/A

LEGEND	
	EXISTING CONTOUR
	EXISTING SPOT ELEVATION
	EXISTING CATCHBASIN
	EXISTING DRAIN MANHOLE
	EXISTING WELL
	EXISTING HAYBALES W/SILT FENCE
	EXISTING WATER SERVICE
	DEEP OBSERVATION TEST HOLE
	T.O.C. TOP OF CONCRETE
	L.O.C. LIMIT OF CLEARING
	EXISTING TREE LINE
	WFB-20 WETLAND FLAG

PUMP INFORMATION:

MANUFACTURER: LITTLE GIANT
MODEL #: 9S-CIA-RFS
INPUT POWER: 115V - 13 AMP


CYCLE TIME: 1 MINUTES 47 SECONDS
DOSE VOLUME: 175 GALLONS
ALARM FUNCTIONAL

PLAN REFERENCE:
PLAN ENTITLED "MISCOE POND ESTATES" LAST REVISED 6/21/82, PREPARED BY SHEA ENGINEERING AND SURVEYING COMPANY, FILED AT THE NORFOLK COUNTY REGISTRY OF DEEDS, DEDHAM MA, AS PLAN NO. 648 OF 1982 PLAN BOOK 297.

DIG SAFE NOTE:
UTILITIES ARE PLOTTED FROM FIELD LOCATION AND ANY RECORD INFORMATION AVAILABLE AND SHOULD BE CONSIDERED APPROXIMATE. OTHER UTILITIES MAY EXIST WHICH ARE NOT EVIDENT OR FOR WHICH RECORD INFORMATION WAS NOT AVAILABLE. CONTRACTORS (IN ACCORDANCE WITH MASS.G.L. CHAPTER 82 SECTION 40 AS AMENDED) MUST CONTACT ALL UTILITY COMPANIES BEFORE EXCAVATING AND DRILLING. ALSO, CALL "DIG-SAFE" AT (888)344-7233 (1(888)DIG-SAFE).


CONSTRUCTION ON THIS LAND IS SUBJECT TO ANY EASEMENTS, RIGHTS-OF-WAY, RESTRICTIONS, RESERVATIONS, OR OTHER LIMITATIONS WHICH MAY BE REVEALED BY AN EXAMINATION OF THE TITLE.

"I certify that this plan is based upon an on the ground instrument survey and that the existing features are located as shown hereon."



Paul B. Otiswood
Professional Land Surveyor

"I hereby certify that this system is constructed in substantial compliance with the design for septic system upgrade dated 09/07/2005 and approved by the Franklin Board of Health"



Gregory A. Bunnick 11-29-05
Professional Engineer

11 CHRIS DRIVE
SEPTIC SYSTEM AS-BUILT
IN
FRANKLIN MA
SCALE: 1"=20'
DATE: NOVEMBER 18, 2005
REV. DATE: DESCRIPTION:

OWNER/APPLICANT ALLISON S
ADDRESS 11 CHRIS DRIVE, FRANKLIN MA



38 POND ST., SUITE 205
(508) 528-3221

FRANKLIN, MASS. 02020
(508) 528-7921

F320